

Permit No. PPC/A/1022412 Dargavel EfW facility  
Scotgen (Dumfries) ltd

**Incident Report Stream 1**

Incident notified by phone Y/N  
Confirmed by 1st class post/Fax Y/N  
Report complete here Y/N

Y
Y
Y

**Nature of the incident**

SCC temperature Breach (1094C)

**Time and duration of the incident**

25/09/10 16:09-11

**Receiving environmental medium or media**

None

**Estimate of quantity and composition**

Detailed by supplied tables

**Measures taken to prevent or minimise emission**

Abatement controls, oxygen control and temperature control, Emissions & Oxygen compliant

**Report of the Investigation**

Refer to attached documentation  
Stage 3 burner issue

**Steps taken to bring the incident to an end**

Reduce fans speeds and bring temperature up before making online repair/cleaning of nozzles

**Proposals for remediation**

Air purge mod to be installed on all SCC burners

**Proposals for preventing a repetition**

Air purge mod to be installed on all SCC burners

**END**

Disclaimer: I hope all the information supplied is suitable if you could please get in touch within 14 working days if requiring further information