

Permit No. PPC/A/1022412 Dargavel EfW facility
Scotgen (Dumfries) ltd

Incident Report Stream 1

Incident notified by phone Y/N
Confirmed by 1st class post/Fax Y/N
Report complete here Y/N

Y
Y
Y

Nature of the incident

SCC temperature Breach (1097C)

Time and duration of the incident

24/09/10 07:40-43

Receiving environmental medium or media

None

Estimate of quantity and composition

Detailed by supplied tables

Measures taken to prevent or minimise emission

Abatement controls, oxygen control and temperature control, Emissions & Oxygen compliant

Report of the Investigation

Refer to attached documentation
Stage 3 burner issue

Steps taken to bring the incident to an end

Reduce fans speeds and bring temperature up before making online repair/cleaning of nozzles

Proposals for remediation

Air purge mod to be installed on all SCC burners

Proposals for preventing a repetition

Air purge mod to be installed on all SCC burners

END

Disclaimer: I hope all the information supplied is suitable if you could please get in touch within 14 working days if requiring further information