

Permit No. PPC/A/1022412 Dargavel EfW facility
Scotgen (Dumfries) ltd

Incident Report Stream 1

Incident notified by phone Y/N
Confirmed by 1st class post/Fax Y/N
Report complete here Y/N

Y
Y
Y

Nature of the incident

SCC temperature Breach (1098C)

Time and duration of the incident

30/09/10 03:40-41 for Temp
30/09/10 03:41-44 for Oxygen
30/09/10 CO 10 minute breach
30/09/10 CO 30 minute breach likely compliant

Receiving environmental medium or media

None

Estimate of quantity and composition

Detailed by supplied tables

Measures taken to prevent or minimise emission

Abatement controls, oxygen control and temperature control, Emissions & Oxygen compliant

Report of the Investigation

Refer to attached documentation
Stage 3 burner issue, only one PGC online and in cooldown mode

Steps taken to bring the incident to an end

Reduce fans speeds and bring temperature up before making online repair/cleaning of nozzles

Proposals for remediation

Air purge mod to be installed on all SCC burners

Proposals for preventing a repetition

Air purge mod to be installed on all SCC burners

END

Disclaimer: I hope all the information supplied is suitable if you could please get in touch within 14 working days if requiring further information