

Permit No. PPC/A/1022412 Dargavel EfW facility
Scotgen (Dumfries) ltd

Incident Report Stream 2

Incident notified by phone Y/N
Confirmed by 1st class post/Fax Y/N
Report complete here Y/N

Y
Y
Y

Nature of the incident

2x 30 min dust breaches and daily breach

Note all 30 minutes should be within % compliance over the year, so no breach

Time and duration of the incident

05/10/10 15:00-30 & 16:00-29

Receiving environmental medium or media

Atmosphere

Estimate of quantity and composition

Detailed by supplied tables

Measures taken to prevent or minimise emission

Abatement controls, oxygen control and temperature control, Temperature & oxygen compliant

Report of the Investigation

Refer to attached documentation
dust spikes due to false readings, conformed by visual on stack and back up probe giving different
much lower and results. Will see if the back up data can be used and what difference this makes.
New dust control box due on Monday

Steps taken to bring the incident to an end

Contacted CBISS arranged for equipment to be replaced, use back up probe data

Proposals for remediation

service contract, QAL 2

Proposals for preventing a repetition

service contract, QAL 2

END

Disclaimer: I hope all the information supplied is suitable if you could please get in touch within 14
working days if requiring further information